


NOTES:

- WHERE TRAIL IS LOCATED OVER BURIED UTILITIES, THE ENTIRE TRENCH SHALL BE BACKFILLED WITH GRANULAR BORROW AND COMPACTED TO 96% DENSITY (SEE SECTION 02230).
- SECTION SHOWN IS FOR TYPICAL CONDITIONS. TRAIL MAY BE MODIFIED TO ACCOMMODATE SITE SPECIFIC REQUIREMENTS.
- DRAINAGE DITCH PARALLEL TO TRAIL MAY BE REQUIRED FOR STORM WATER. MINIMUM WIDTH DITCH IS 3 FT OR AS APPROVED BY THE ENGINEER. BANK SLOPE EACH SIDE OF CENTERLINE OF DITCH WITH SIDE SLOPES OF 4H:1V.
- SURFACING COURSE MATERIAL DEPTH AND SIZE SHOWN IS MINIMUM REQUIREMENT. ACTUAL SIZE MAY VARY PER SITE SPECIFIC CONDITIONS.
- STAKE ALIGNMENT AND CLEARING LIMITS IN THE FIELD PRIOR TO CLEARING.
- SUBGRADE AND BASE COURSE COMPACTION MUST BE TESTED IN ACCORDANCE WITH SANDY STANDARD SPECIFICATIONS..

1	C. Kirk	DWG REVISION	5/1/17	
NO.	AUTHORIZED BY	REVISIONS	DATE	

STANDARD DETAIL
PARKS & RECREATION
TR-03
PEDESTRIAN
WALKING/HIKING TRAIL